



Public Health
Prevent. Promote. Protect.

Hendricks County Health Department

Hendricks County Health Department
355 S Washington St Ste G30
Danville, IN 46122
(317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

**Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and
Hendricks County Public Pool and Spa Ordinance 2003-27**

Pool Name: Avon Creek Apartment Pool

Permit Number: 4

Size: Under 2000 sqft

Pool Type: Outdoor Pool

Purpose: Routine

Complaint #

<u>Pool Water Chemistry (Section 30)</u>		<u>Lifesaving and Safety Equipment (Section 34)</u>		
Operating Records		Satisfactory	Life Pole	Satisfactory
Test Kit		Satisfactory	Ring Buoy with Rope	Satisfactory
Disinfectant	6.81 ppm	Satisfactory	Spine Board, Straps & Head Immobilize	Satisfactory
Combined Chlorine	0.10 ppm	Satisfactory	First Aid Kit with Two (2) Blankets	Satisfactory
pH	7.7	Satisfactory	Telephone	Satisfactory
Total Alkalinity	120 ppm	Satisfactory	Depth Markings	Satisfactory
Calcium Hardness	290 ppm		Transition Line	N/A
Cyanuric Acid	59 ppm	Satisfactory		
Disinfectant Type		Tri-Chlor	<u>Lifeguards (Section 35)</u>	
<u>Chemical Storage (Section 33)</u>			Lifeguard(s) Present	N/A
All Items 6 Inches Above Floor		Satisfactory	Lifeguard Platform or Chair	N/A
<u>Sanitary Facilities (Section 29)</u>			<u>Water Quality /Cleaning (Sections 31 & 37)</u>	
Supplies and Water		Satisfactory	Main Drain	Satisfactory
Safe and Sanitary Condition		Satisfactory	Inside Surfaces	Satisfactory
<u>Warning Signs (Section 36)</u>			Skimmers / Gutters	Satisfactory
User Sanitation and Safety Rules		Satisfactory	Temperature °F	N/A
Warning Signs		Satisfactory		

Bacteria Samples:	06/07/2022	05/31/2022	05/24/2022	05/19/2022	05/18/2022	99/99/2022
(Section 31)	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	

Violation Narrative

Pool is Operational.

Inspector: Other Inspector's Signature:
Copy of report sent to:

Date of Inspection June 17, 2022