



Public Health
Prevent. Promote. Protect.

Hendricks County Health Department

Hendricks County Health Department
355 S Washington St Ste G30
Danville, IN 46122
(317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

**Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and
Hendricks County Public Pool and Spa Ordinance 2003-27**

Pool Name: Avon High School

Permit Number: 5

Size: 2000 sqft and over

Pool Type: Indoor Pool

Purpose: Routine

Complaint #

<u>Pool Water Chemistry (Section 30)</u>			<u>Lifesaving and Safety Equipment (Section 34)</u>		
Operating Records		Satisfactory	Life Pole		Satisfactory
Test Kit		Satisfactory	Ring Buoy with Rope		Satisfactory
Disinfectant	2.74 ppm	Satisfactory	Spine Board, Straps & Head Immobilize		Satisfactory
Combined Chlorine	.11 ppm	Satisfactory	First Aid Kit with Two (2) Blankets		Satisfactory
pH	7.6	Satisfactory	Telephone		Satisfactory
Total Alkalinity	31 ppm	Satisfactory Based on Saturation Index	Depth Markings		Satisfactory
Calcium Hardness	342 ppm		Transition Line		Satisfactory
Cyanuric Acid	N/A ppm	N/A			
Disinfectant Type		Calcium Hypochlorite	<u>Lifeguards (Section 35)</u>		
<u>Chemical Storage (Section 33)</u>			Lifeguard(s) Present		N/A
All Items 6 Inches Above Floor		Satisfactory	Lifeguard Platform or Chair		Satisfactory
<u>Sanitary Facilities (Section 29)</u>			<u>Water Quality /Cleaning (Sections 31 & 37)</u>		
Supplies and Water		Satisfactory	Main Drain		Satisfactory
Safe and Sanitary Condition		Satisfactory	Inside Surfaces		Unsatisfactory
<u>Warning Signs (Section 36)</u>			Skimmers / Gutters		Satisfactory
User Sanitation and Safety Rules		Satisfactory	Temperature	79.1°F	N/A
Warning Signs		Satisfactory			

<u>Bacteria Samples:</u>	09/27/2022	09/21/2022	09/14/2022	09/07/2022	08/30/2022	08/23/2022
(Section 31)	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory

Violation Narrative

Total alkalinity is satisfactory based on Saturation Index.

410 IAC 6-2.1-37 (a) Visible dirt on the bottom and walls of the pool shall be removed at least every twenty-four (24) hours or more frequently if required.

Pool is Operational.

Inspector: Sarah Dallas
Copy of report sent to:

Inspector's Signature:
J Karr; J Larsh

Sarah Dallas, RTHSCPO

Date of Inspection

October 6, 2022