



Hendricks County Health Department
355 S Washington St Ste G30
Danville, IN 46122
(317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and
Hendricks County Public Pool and Spa Ordinance 2003-27

Pool Name: Avon High School

Permit Number: 5

Size: 2000 sqft and over

Pool Type: Indoor Pool

Purpose: Routine

Complaint #

<u>Pool Water Chemistry (Section 30)</u>			<u>Lifesaving and Safety Equipment (Section 34)</u>		
Operating Records		Satisfactory	Life Pole		Satisfactory
Test Kit		Satisfactory	Ring Buoy with Rope		Satisfactory
Disinfectant	0.46 ppm	Unsatisfactory	Spine Board, Straps & Head Immobilize		Satisfactory
Combined Chlorine	0.06 ppm	Satisfactory	First Aid Kit with Two (2) Blankets		Satisfactory
pH	7.5	Satisfactory	Telephone		Unsatisfactory
Total Alkalinity	32 ppm	Unsatisfactory	Depth Markings		Satisfactory
Calcium Hardness	314 ppm		Transition Line		Satisfactory
Cyanuric Acid	ppm	N/A			
Disinfectant Type	Calcium Hypochlorite				
<u>Chemical Storage (Section 33)</u>			<u>Lifeguards (Section 35)</u>		
All Items 6 Inches Above Floor		Satisfactory	Lifeguard(s) Present		N/A
			Lifeguard Platform or Chair		Satisfactory
<u>Sanitary Facilities (Section 29)</u>			<u>Water Quality /Cleaning (Sections 31 & 37)</u>		
Supplies and Water		Satisfactory	Main Drain		Satisfactory
Safe and Sanitary Condition		Satisfactory	Inside Surfaces		Satisfactory
<u>Warning Signs (Section 36)</u>			Skimmers / Gutters		Satisfactory
User Sanitation and Safety Rules		Satisfactory	Temperature 79°F		N/A
Warning Signs		Satisfactory			

<u>Bacteria Samples:</u>	09/07/2022	08/30/2022	08/23/2022	08/16/2022	08/09/2022	08/02/2022
(Section 31)	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory

Violation Narrative

410 IAC 6-2.1-43 Pool must be closed until disinfectant is within range.

410 IAC 6-2.1-30 (n) The alkalinity of the water in pools shall be at least eighty (80) ppm and no more than one hundred twenty (120) ppm.

410 IAC 6-2.1-34 (e) A telephone shall be located within two hundred (200) feet of the pool enclosure and must be available for emergency use whenever the pool is open for use.

Pool is Closed. Disinfectant too low

Inspector: Sarah Dallas
Copy of report sent to:

Inspector's Signature:
J Karr; J Larsh

Sarah Dallas, RHTS, CPO

Date of Inspection

September 15, 2022