



Hendricks County Health Department  
355 S Washington St Ste G30  
Danville, IN 46122  
(317) 745-9217 FAX (317) 745-9218

## Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and  
Hendricks County Public Pool and Spa Ordinance 2003-27

Pool Name: Avon High School

Permit Number: 5

Size: 2000 sqft and over

Pool Type: Indoor Pool

Purpose: Routine

Complaint #

| <u>Pool Water Chemistry (Section 30)</u> |          |                      | <u>Lifesaving and Safety Equipment (Section 34)</u>   |        |                |
|--|----------|----------------------|---|--------|----------------|
| Operating Records                        |          | Satisfactory         | Life Pole   |        | Satisfactory   |
| Test Kit                                 |          | Satisfactory         | Ring Buoy with Rope                                   |        | Satisfactory   |
| Disinfectant                             | 1.72 ppm | Satisfactory         | Spine Board, Straps & Head Immobilize                 |        | Satisfactory   |
| Combined Chlorine                        | 0.04 ppm | Satisfactory         | First Aid Kit with Two (2) Blankets                   |        | Satisfactory   |
| pH                                       | 7.3      | Satisfactory         | Telephone   |        | Unsatisfactory |
| Total Alkalinity                         | 37 ppm   | Unsatisfactory       | Depth Markings  |        | Satisfactory   |
| Calcium Hardness                         | 255 ppm  |                      | Transition Line                                       |        | Satisfactory   |
| Cyanuric Acid                            |          | N/A                  |   |        |                |
| Disinfectant Type                        |          | Calcium Hypochlorite | <u>Lifeguards (Section 35)</u>                        |        |                |
| <u>Chemical Storage (Section 33)</u>     |          |                      | Lifeguard(s) Present                                  |        | N/A            |
| All Items 6 Inches Above Floor           |          | Satisfactory         | Lifeguard Platform or Chair                           |        | Satisfactory   |
| <u>Sanitary Facilities (Section 29)</u>  |          |                      | <u>Water Quality /Cleaning (Sections 31 &amp; 37)</u> |        |                |
| Supplies and Water                       |          | Satisfactory         | Main Drain  |        | Satisfactory   |
| Safe and Sanitary Condition              |          | Satisfactory         | Inside Surfaces                                       |        | Satisfactory   |
| <u>Warning Signs (Section 36)</u>        |          |                      | Skimmers / Gutters                                    |        | Satisfactory   |
| User Sanitation and Safety Rules         |          | Satisfactory         | Temperature   | 78.2°F | N/A            |
| Warning Signs                            |          | Satisfactory         |   |        |                |

| <u>Bacteria Samples:</u> | 08/09/2022   | 08/02/2022   | 07/26/2022   | 07/19/2022   | 07/12/2022   | 07/05/2022   |
|--------------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| <b>(Section 31)</b>      | Satisfactory | Satisfactory | Satisfactory | Satisfactory | Satisfactory | Satisfactory |

### Violation Narrative

410 IAC 6-2.1-30 (n) The alkalinity of the water in pools shall be at least eighty (80) ppm and no more than one hundred twenty (120) ppm.

410 IAC 6-2.1-34 (e) A telephone shall be located within two hundred (200) feet of the pool enclosure and must be available for emergency use whenever the pool is open for use.

Emergency phone was broken open and not operating.  
Pool is Operational.

Inspector: Sarah Dallas  
Copy of report sent to:

Inspector's Signature: Jon Karr

*Sarah Dallas, REHS, CEO*

Date of Inspection

August 17, 2022