



Public Health
Prevent. Promote. Protect.

Hendricks County Health Department

Hendricks County Health Department
355 S Washington St Ste G30
Danville, IN 46122
(317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and
Hendricks County Public Pool and Spa Ordinance 2003-27

Pool Name: Avon High School
Size: 2000 sqft and over
Purpose: Routine

Permit Number: 5
Pool Type: Indoor Pool
Complaint #

<u>Pool Water Chemistry (Section 30)</u>		<u>Lifesaving and Safety Equipment (Section 34)</u>	
Operating Records	Satisfactory	Life Pole	Satisfactory
Test Kit	Satisfactory	Ring Buoy with Rope	Satisfactory
Disinfectant	2.38 ppm	Spine Board, Straps & Head Immobilize	Satisfactory
Combined Chlorine	0.04 ppm	First Aid Kit with Two (2) Blankets	Satisfactory
pH	7.4	Telephone	Satisfactory
Total Alkalinity	84 ppm	Depth Markings	Satisfactory
Calcium Hardness		Transition Line	Satisfactory
Cyanuric Acid	N/A		
Disinfectant Type	Calcium Hypochlorite	<u>Lifeguards (Section 35)</u>	
<u>Chemical Storage (Section 33)</u>		Lifeguard(s) Present	N/A
All Items 6 Inches Above Floor	Satisfactory	Lifeguard Platform or Chair	Satisfactory
<u>Sanitary Facilities (Section 29)</u>		<u>Water Quality /Cleaning (Sections 31 & 37)</u>	
Supplies and Water	Satisfactory	Main Drain	Satisfactory
Safe and Sanitary Condition	Satisfactory	Inside Surfaces	Satisfactory
<u>Warning Signs (Section 36)</u>		Skimmers / Gutters	Satisfactory
User Sanitation and Safety Rules	Satisfactory	Temperature °F	N/A
Warning Signs	Satisfactory		

<u>Bacteria Samples:</u>	06/14/2022	06/07/2022	05/31/2022	05/24/2022	05/17/2022	05/10/2022
<u>(Section 31)</u>	Unsatisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory

Violation Narrative

Pool is Operational.

Inspector: Sarah Dallas
Copy of report sent to:

Inspector's Signature: Jon Karr

Date of Inspection

June 17, 2022