

Pool Name:

Hendricks County Health Department 355 S Washington St Ste G30 Danville, IN 46122 (317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and

Hendricks County Public Pool and Spa Ordinance 2003-27 Avon High School

Permit Number: 5

Size: 2000 sqft and over Pool Type: Indoor Pool

Purpose: Routine Complaint #

Pool Water Chemistry	(Section 30)		Lifesaving and Safety Equipment (Section 34)			
Operating Records		Satisfactory	Life Pole	Satisfactory		
Test Kit		Satisfactory	Satisfactory Ring Buoy with Rope			
Disinfectant	2.77 ppm	Satisfactory	Spine Board, Straps & Head Immobilize	Satisfactory		
Combined Chlorine	0.24 ppm	Satisfactory	First Aid Kit with Two (2) Blankets	Unsatisfactory		
pН	7.3	Satisfactory	Telephone	Satisfactory		
Total Alkalinity	50 ppm	Unsatisfactory	Depth Markings	Satisfactory		
Calcium Hardness 291 ppm			Transition Line	Satisfactory		
Cyanuric Acid		N/A				
Disinfectant Type		Calcium Hypochlorite	Lifeguards (Section 35)			
Chemical Storage (Section 33)		Lifeguard(s) Present		N/A		
All Items 6 Inches Above Floor		Satisfactory	Lifeguard Platform or Chair	Satisfactory		
Sanitary Facilities (Section 29)			Water Quality / Cleaning (Sections 31 & 3	<u>7)</u>		
Supplies and Water		Satisfactory Main Drain		Satisfactory		
Safe and Sanitary Condition		Satisfactory	Inside Surfaces	Unsatisfactory		
Warning Signs (Section 36)		Skimmers / Gutters		Satisfactory		
User Sanitation and Safety Rules		Satisfactory	Temperature 77.3°F	N/A		
Warning Signs		Satisfactory				
Bacteria Samples:	05/03/2022	04/27/2022 04/	19/2022 04/12/2022 04/05/2022	03/29/2022		

Bacteria Samples:	05/03/2022	04/27/2022	04/19/2022	04/12/2022	04/05/2022	03/29/2022
(Section 31)	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory

Violation Narrative

410 IAC 6-2.1-30 (n) The alkalinity of the water in pools shall be at least eighty (80) ppm and no more than one hundred twenty (120) ppm.

410 IAC 6-2.1-37 (a) Visible dirt on the bottom and walls of the pool shall be removed at least every twenty-four (24)hours or more frequently if required.

410 IAC 6-2.1-34 (d) A twenty-four (24) unit first aid kit that meets American National Standards Institute (ANSI) standard Z308.1-2003 or 2009 and two (2) blankets shall be provided within each pool enclosure. The first aid kit shall be kept filled and ready for use whenever the pool is open for use.

Provide more bandaids for first aid kit.

Pool is Operational.

Inspector: Sarah Dallas Inspector's Signature:

Copy of report sent to: Jon Karr

Date of Inspection May 10, 2022

Such Dellas, REPS, CPO