

Hendricks County Health Department 355 S Washington St Ste G30 Danville, IN 46122 (317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and Hendricks County Public Pool and Spa Ordinance 2003-27

Pool Name: Avon High School Permit Number: 5 Size: 2000 sqft and over **Pool Type: Indoor Pool**

Complaint # **Purpose:** Routine

| Pool Water Chemistry (Section 30) | | | | <u>Lifesaving and Safety Equipment (Section 34)</u> | | | |
|--|----------------|---|---------------------------------------|---|--------------|--------------|--|
| Operating Records | | Satisfactory | Life Pole | | Satisfactory | | |
| Test Kit | | Satisfactory | Ring Buoy with Rope | | Satisfactory | | |
| Disinfectant | 1.64 ppm | Satisfactory | Spine Board, Straps & Head Immobilize | | Satisfactory | | |
| Combined Chlorine | 0.40 ppm | Satisfactory | First Aid Kit with Two (2) Blankets | | lankets | Satisfactory | |
| pН | 7.4 | Satisfactory | Telephone | | | Satisfactory | |
| Total Alkalinity | 61 ppm | Satisfactory Based or | n Depth Markings | | | Satisfactory | |
| | | Saturation Index | | | | | |
| Calcium Hardness | 291 ppm | | Transition Line | | | Satisfactory | |
| Cyanuric Acid | | N/A | | | | | |
| Disinfectant Type | | Calcium Hypochlorite | Lifeguards (Section 35) | | | | |
| Chemical Storage (Section 33) All Items 6 Inches Above Floor | | Lifeguard(s) Present | | | N/A | | |
| | | Satisfactory | Lifeguard Platform or Chair | | | Satisfactory | |
| Sanitary Facilities (| Section 29) | Water Quality / Cleaning (Sections 31 & 37) | | | | 1 | |
| Supplies and Water | | Satisfactory | Main Drain | | Satisfactory | | |
| Safe and Sanitary Condition | | Satisfactory Inside Surfaces | | Satisfactory | | | |
| Warning Signs (Sect | <u>ion 36)</u> | Skimmers / Gutters | | | Satisfactory | | |
| User Sanitation and Safety Rules | | Satisfactory Temperature 81°F | | | N/A | | |
| Warning Signs | | Satisfactory | 7 | | | | |
| Bacteria Samples: | 04/05/2022 | 03/29/2022 03 | /22/2022 | 03/15/2022 | 03/08/2022 | 03/01/2022 | |
| (Section 31) | Satisfactory | Satisfactory Sa | tisfactory | Satisfactory | Satisfactory | Satisfactory | |

Violation Narrative

Sarah Dallas, REHS, CPO

Total alkalinity is satisfactory based on Saturation Index.

Pool is Operational.

Inspector: Sarah Dallas Inspector's Signature:

Copy of report sent to: Jon Karr

April 12, 2022 Date of Inspection