



Hendricks County Health Department
355 S Washington St Ste G30
Danville, IN 46122
(317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and
Hendricks County Public Pool and Spa Ordinance 2003-27

Pool Name: Avon High School

Permit Number: 5

Size: 2000 sqft and over

Pool Type: Indoor Pool

Purpose: Routine

Complaint #

<u>Pool Water Chemistry (Section 30)</u>		<u>Lifesaving and Safety Equipment (Section 34)</u>		
Operating Records		Satisfactory	Life Pole	Satisfactory
Test Kit		Satisfactory	Ring Buoy with Rope	Satisfactory
Disinfectant	2.57 ppm	Satisfactory	Spine Board, Straps & Head Immobilize	Satisfactory
Combined Chlorine	0.16 ppm	Satisfactory	First Aid Kit with Two (2) Blankets	Satisfactory
pH	7.5	Satisfactory	Telephone	Satisfactory
Total Alkalinity	93 ppm	Satisfactory	Depth Markings	Satisfactory
Calcium Hardness			Transition Line	Satisfactory
Cyanuric Acid		N/A		
Disinfectant Type	Calcium Hypochlorite		<u>Lifeguards (Section 35)</u>	
<u>Chemical Storage (Section 33)</u>			Lifeguard(s) Present	N/A
All Items 6 Inches Above Floor	Satisfactory		Lifeguard Platform or Chair	Satisfactory
<u>Sanitary Facilities (Section 29)</u>			<u>Water Quality /Cleaning (Sections 31 & 37)</u>	
Supplies and Water	Satisfactory		Main Drain	Satisfactory
Safe and Sanitary Condition	Satisfactory		Inside Surfaces	Unsatisfactory
<u>Warning Signs (Section 36)</u>			Skimmers / Gutters	Satisfactory
User Sanitation and Safety Rules	Satisfactory		Temperature	80.6°F
Warning Signs	Satisfactory			N/A

<u>Bacteria Samples:</u>	02/08/2022	01/31/2022	01/25/2022	01/18/2022	01/11/2022	01/04/2022
(Section 31)	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory

Violation Narrative

410 IAC 6-2.1-37 (a) Visible dirt on the bottom and walls of the pool shall be removed at least every twenty-four (24) hours or more frequently if required.

Pool is Operational.

Inspector: Sarah Dallas
Copy of report sent to:

Inspector's Signature:
Jon Karr

Sarah Dallas, REHS, CPO / Devin Brennan

Date of Inspection

February 14, 2022