



**Public Health**  
Prevent. Promote. Protect.

Hendricks County Health Department

Hendricks County Health Department  
355 S Washington St Ste G30  
Danville, IN 46122  
(317) 745-9217 FAX (317) 745-9218

### Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and  
Hendricks County Public Pool and Spa Ordinance 2003-27

Pool Name: Avon Creek

Permit Number: 4

Size: Under 2000 sqft

Pool Type: Outdoor Pool

Purpose: Routine

Complaint #

<u>Pool Water Chemistry (Section 30)</u>			<u>Lifesaving and Safety Equipment (Section 34)</u>		
Operating Records		Satisfactory	Life Pole		Satisfactory
Test Kit		Satisfactory	Ring Buoy with Rope		Satisfactory
Disinfectant	7+ ppm	Satisfactory	Spine Board, Straps & Head Immobilize		Satisfactory
Combined Chlorine	.0 ppm	Satisfactory	First Aid Kit with Two (2) Blankets		Satisfactory
pH	7.4	Satisfactory	Telephone		Satisfactory
Total Alkalinity	159 ppm	Satisfactory Based on Saturation Index	Depth Markings		Satisfactory
Calcium Hardness	224 ppm		Transition Line		N/A
Cyanuric Acid	59 ppm	Satisfactory			
Disinfectant Type		Tri-Chlor	<u>Lifeguards (Section 35)</u>		
<u>Chemical Storage (Section 33)</u>			Lifeguard(s) Present		N/A
All Items 6 Inches Above Floor		Satisfactory	Lifeguard Platform or Chair		N/A
<u>Sanitary Facilities (Section 29)</u>			<u>Water Quality /Cleaning (Sections 31 &amp; 37)</u>		
Supplies and Water		Satisfactory	Main Drain		Satisfactory
Safe and Sanitary Condition		Satisfactory	Inside Surfaces		Satisfactory
<u>Warning Signs (Section 36)</u>			Skimmers / Gutters		Satisfactory
User Sanitation and Safety Rules		Satisfactory	Temperature	77.4°F	Satisfactory
Warning Signs		Satisfactory			

<u>Bacteria Samples:</u>	08/09/2022	08/02/2022	07/26/2022	07/19/2022	07/12/2022	07/05/2022
<u>(Section 31)</u>	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory

#### Violation Narrative

Total alkalinity is satisfactory based on Saturation Index.  
Pool is Operational.

Inspector: Other Inspector's Signature:  
Copy of report sent to:

Date of Inspection August 17, 2022