

Hendricks County Health Department 355 S Washington St Ste G30 Danville, IN 46122 (317) 745-9217 FAX (317) 745-9218

Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and

| | Hendricks County Public Pool and Spa Ordinance 2003-27 | |
|------------|--|------------------|
| Pool Name: | Avon Creek | Permit Number: 4 |

| Size: | Under 2000 sqft |
|----------|-----------------|
| Purpose: | Routine |

Pool Type: Outdoor Pool

Complaint #

| Pool Water Chemistry | v (Section 30) | | Lifesaving and Safety Equipment (Section 34) | | | |
|----------------------------------|-------------------|--|--|--------------|--------------|--------------|
| Operating Records | | Satisfactory | Life Pole | | | Satisfactory |
| Test Kit | | Satisfactory | Ring Buoy with Rope | | | Satisfactory |
| Disinfectant | 1.98 ppm | Satisfactory | Spine Board, Straps & Head Immobilize | | | Satisfactory |
| Combined Chlorine | .21 ppm | Satisfactory | First Aid Kit | lankets | Satisfactory | |
| pH | 7.6 | Satisfactory | Telephone | | | Satisfactory |
| Total Alkalinity | 142 ppm | Satisfactory Based on | Depth Markings | | | Satisfactory |
| | | Saturation Index | | | | |
| Calcium Hardness | 194 ppm | | Transition Line | | | N/A |
| Cyanuric Acid | 60 ppm | Satisfactory | | | | |
| Disinfectant Type | | Tri-Chlor | Lifeguards (Section 35) | | | |
| <u>Chemical Storage (S</u> | <u>ection 33)</u> | | Lifeguard(s) Present | | | N/A |
| All Items 6 Inches Ab | ove Floor | Satisfactory | Lifeguard Platform or Chair | | | N/A |
| <u>Sanitary Facilities (</u> | Section 29) | Water Quality /Cleaning (Sections 31 & 37) | | | | 1 |
| Supplies and Water | | Satisfactory | Main Drain | | Satisfactory | |
| Safe and Sanitary Condition | | Satisfactory | Satisfactory Inside Surfaces | | | Satisfactory |
| Warning Signs (Sect | <u>ion 36)</u> | | Skimmers / Gutters | | | Satisfactory |
| User Sanitation and Safety Rules | | Satisfactory Temperature 80.6°F | | | Satisfactory | |
| Warning Signs Satisfactory | | | | | | |
| Bacteria Samples: | 07/26/2022 | 07/19/2022 07/ | 12/2022 | 07/05/2022 | 06/28/2022 | 06/21/2022 |
| (Section 31) | Satisfactory | Satisfactory Sat | isfactory | Satisfactory | Satisfactory | Satisfactory |

Violation Narrative

Total alkalinity is satisfactory based on Saturation Index.

Other

Pool is Operational.

Inspector:

Ky Km

Inspector's Signature: Copy of report sent to:

Date of Inspection

August 3, 2022