



Hendricks County Health Department  
355 S Washington St Ste G30  
Danville, IN 46122  
(317) 745-9217 FAX (317) 745-9218

### Swimming Pool Inspection Form

Inspection based on Indiana State Department of Health 410 IAC 6-2.1 and  
Hendricks County Public Pool and Spa Ordinance 2003-27

Pool Name: Avon High School

Permit Number: 5

Size: 2000 sqft and over

Pool Type: Indoor Pool

Purpose: Routine

Complaint #

<u>Pool Water Chemistry (Section 30)</u>			<u>Lifesaving and Safety Equipment (Section 34)</u>	
Operating Records		Satisfactory	Life Pole	Satisfactory
Test Kit		Satisfactory	Ring Buoy with Rope	Satisfactory
Disinfectant	3.06 ppm	Satisfactory	Spine Board, Straps & Head Immobilize	Satisfactory
Combined Chlorine	.08 ppm	Satisfactory	First Aid Kit with Two (2) Blankets	Satisfactory
pH	7.6	Satisfactory	Telephone	Satisfactory
Total Alkalinity	88 ppm	Satisfactory	Depth Markings	Satisfactory
Calcium Hardness	N/A ppm		Transition Line	Satisfactory
Cyanuric Acid	ppm	N/A		
Disinfectant Type	Calcium Hypochlorite		<u>Lifeguards (Section 35)</u>	
<u>Chemical Storage (Section 33)</u>			Lifeguard(s) Present	N/A
All Items 6 Inches Above Floor	Satisfactory		Lifeguard Platform or Chair	Satisfactory
<u>Sanitary Facilities (Section 29)</u>			<u>Water Quality /Cleaning (Sections 31 &amp; 37)</u>	
Supplies and Water	Satisfactory		Main Drain	Satisfactory
Safe and Sanitary Condition	Satisfactory		Inside Surfaces	Satisfactory
<u>Warning Signs (Section 36)</u>			Skimmers / Gutters	Satisfactory
User Sanitation and Safety Rules	Satisfactory		Temperature 81°F	Satisfactory
Warning Signs	Satisfactory			

<b>Bacteria Samples:</b>	01/04/2022	12/28/2021	12/21/2021	12/14/2021	12/07/2021	11/30/2021
<b>(Section 31)</b>	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory	Satisfactory

#### Violation Narrative

No violations at time of inspection.

Pool is Operational.

Inspector: Devin Brennan

Inspector's Signature:

Copy of report sent to:

Jon Karr

Date of Inspection

January 11, 2022